

Etowah Utilities Board Sewer Pretreatment Criteria and Sewer Use Ordinance			
			2018
Pollutant	Plant Local Limits		Plant Local Limits
	milligrams/liter		milligrams/lite
	Monthly Average		Daily Maximun
Copper	0.53		0.79
Chromium III	2		3
Chromium VI	0.43		0.64
Nickel	0.51		0.76
Cadmium	0.042		0.063
Lead	0.77		1.15
Mercury	0.0033		0.005
Zinc	0.55		0.83
Silver	0.078		0.117
Cyanide	0.095		0.142
Toluene	0.44		0.65
Benzene	0.026		0.039
1,1,1-Trichloroethane	0.51		0.76
Ethybenzene	0.41		0.61
Carbon Tetrachloride	0.34		0.51
Chloroform	8.7		13
Tetrachloroethylene	0.28		0.42
Trichlorethylene	0.2		0.31
1,2 Transdichloroethylene	0.015		0.022
Methylene chloride	0.2		0.29
Phenol	1.11		1.67
Naphthalene	0.04		0.06
Bis(2-ethyl hexyl) phthalate	Report		Report
Butyl benzyl phthalate	Report		Report
Di-n-butyl phthalate	Report		Report
Diethyl phthalate	Report		Report
Total Phthalate	0.34		0.52
Ammonia *	35.7		53.5
*Case by case determination			